

**Frederick County
Dry Hydrants**

Fire Sta	Lat	Long	Location	Verified		Connection
				Lat	Long	Size
01	39.26.20	77.28.27	Lakeview Drive	39.26.275	77.31.667	6"Female
	Location:	Between Somerset Terr. And Hillside Dr				
	Other Info:	Est Flow 1000gpm Est. Capacity 2,036,880gals				
05	39.20.5	77.36.48	Rosemont Lions Club on Petersville Road	39.20.404	77.36.789	6" Male
	Location:	4000 blk of Pertersville Rd				
	Other Info:	Est Flow 600gpm Est Capacity 1,071,315gals				
07	39.23.35	77.37.48	Burkittsville Community Pond	39.23.601	77.37.806	6"Female
	Location:	Lake Side Dr and Burkkitsville Rd				
	Other Info:	Lay out from Main St and Burkkitsville Rd 400ft				
		Est Flow 1000gpm Est. Capacity 448,380gals				
07	39.24.13	77.37.45	6319 Mountain Curch Rd	39.28.248	77.35.985	6"Female
	Location:	Char-Mar Dairy on Mountain Church Road				
	Other Info:	Lay out from parking lot after pond back to hydrant 325ft				
		Est. Flow 1000gpm Est. Capacity 290,250gals				
07	39.26.41	77.31.45	In community pond at Middletown Park	39.26.657	77.31.768	4.5" Male
	Location:	Off of Coblentz Rd				
	Other Info:	Est. Flow 900gpm Est. Capacity 1,339,200gals				

**Frederick County
Dry Hydrants**

				Verified		Connection
Fire Sta	Lat	Long	Location	Lat	Long	Size
07	39.28.14	77.35.59	Near 2085 Old National Pike	39.29.004	7735.417	6" Male
	Location:					
	Other Info:	Est. Flow 800gpm Est, Capacity 794,205gals				
08	39.28.59	77.35.26	9201 Frostown Rd	39.29.751	77.32.810	6" Male
	Location:					
	Other Info:	Est. Flow 1000gpm Est. Capacity 182,315gals				
08	39.30.55	77.28.50	Intersection of Hamburg & Fishing Creek Roads	39.30.916	77.29.321	6" Male
	Location:					
	Other Info:	Unable to pump hydrant pad lock on it cannot locate key				
09	39.33.35	77.12.12	12000 block of Beaver Dam Road	39.34.977	77.13.518	6"Female
	Location:					
	Other Info:	Hydrant # 9-9-A				
		Est. Flow 1000gpm Est. Capacity 408,000gals				
09	39.35.28	77.14.34	13000 blk of Woodsboro Pike	39.33.573	77.12.200	6"Female
	Location:	Hydrant # 9-13-A 'On bridge over Little Pipe Creek on Route 194				
	Other Info:	Did not pump heavy traffic on major route Chief 9 advised hydrant not working well due to lift.				

**Frederick County
Dry Hydrants**

Fire Sta	Lat	Long	Location	Verified		Connection
				Lat	Long	Size
09	39.34.59	77.13.32	12500 blk of Simpsons Mill Road	39.34.417	77.17.758	6"Female
	Location:	Near the intersection of Johnsville Rd and Simpsons Mill Rd				
	Other Info:	Est. Flow 800gpm Est. Capacity Unlimited out of Little Pipe Creek.				
09	39.33.48	77.17.42	12045 Woodsboro Pike	39.29.043	77.11.132	6"Female
	Location:	At New Midway VFC Station to the rear of station				
	Other Info:	Est. Flow 800gpm Est. Capacity 1,698,937gals				
09	39.34.26	77.17.43	12337 Legore Road	39.34.427	77.17.728	6"Female
	Location:					
	Other Info:	Hydrant # 9-1-A Lay in from road to hydrant 600ft				
		Est. Flow 900gpm Est. Capacity 4,941,450gals				
10	39.37.16	77.25.26	500 blk of West Main St	39.37.255	77.25.457	4.5 Male
	Location:	Frank Bentz Pond, near Pryor Road				
	Other Info:	Est Flow 600gpm Capacity unlimited in pond at end of Hunting Creek				
10	39.37.2	77.27.46	Next to Boat Ramp on Catoctin Hollow Road	39.37.252	77.25.450	6"Female
	Location:	At Hunting Creek Lake				
	Other Info:	Est Flow 1000gpm Capacity unlimited in Hunting Creek Lake				

**Frederick County
Dry Hydrants**

Fire Sta	Lat	Long	Location	Verified		Connection
				Lat	Long	Size
10	39.38.28	77.23.37	Roddy Road, near Roddy Covered Bridge	39.38.458	77.23.612	6" Male
	Location:	At The intersection of Roddy Rd and Roddy Creek Rd				
	Other Info:	NOTE NEEDS CAP				
		Est Flow 600gpm Capacity unlimited in Owens Creek				
10	39.40.33	77.27.32	16000 blk of Foxville-Deerfield Rd	39.40.544	77.27.510	6"Female
	Location:	'At bridge over Owens Creek closer to Rt550 on Foxville-Deerfield Rd				
	Other Info:					
		Est Flow 600gpm Capacity unlimited in Owens Creek				
11	39.27.5	77.19.35	7907 Dance Hall Road	39.16.858	77.21.544	6"Female
	Location:	7916 Dance Hall Rd				
	Other Info:					
		Est Flow 800gpm Est Capacity 352,00gals				
13	39.36.21	77.19.25	Western fire pond on Route 77 in Rocky Ridge	39.36.339	77.19.394	4.5 Male
	Location:	Across from 9843 Rocky Ridge Rd				
	Other Info:					
		Est Flow 500gpm Est Capacity 125,062gals				
13	39.36.18	77.19.0	Eastern fire pond on Route 77 in Rocky Ridge	39.36.303	77.18.999	4.5Male
	Location:	Acrss from 10026 Rocky Ridge Rd				
	Other Info:	NOTE FREDERICK CITY THREADS				
		Est Flow 500gpm Est Capacity 359,625gals				

**Frederick County
Dry Hydrants**

				Verified		Connection
Fire Sta	Lat	Long	Location	Lat	Long	Size
14	39.18.25	77.30.49	4701 East Basford Road			
	Location:					
	Other Info:	NOTE NOT ACCESSABLE BY FIRE APPARATUS				
14	39.16.38	77.28.46	1550 New Design Road	39.21.892	77.23.950	6"Female
	Location:	Go pass the drive to house make a right at the shop go to B/C corner at the end of parking lot				
	Other Info:					
		Est Flow 700gpm Est Capacity 3,071,250gals				
14	39.15.49	77.26.2	1200 blk of Park Mills Road	39.15.939	77.26.069	6"Female
	Location:	At Monocacy Boat Ramp				
	Other Info:	NOTE Needs sign on Park Mills Rd for hydrant				
		Est Flow 600gpm Est Capacity unlimited in Monocacy River				
15			Emory Alley	39.21.526	77.15.898	6"Female
	Location:	At the town fire pond				
	Other Info:					
		Est Flow 600gpm Est Capacity 873,180gals				
17			Life In Jesus Church 9002 Clemsonville Road	39.29.218	77.14.505	4.5 Male
	Location:	Hydrant at split in driveway below pond/ Saint Benedict Way				
	Other Info:	Is an actual Fire Hydrant with static supply from pond.				
		Est Flow 500gpm Est Capacity 138,000gals				

**Frederick County
Dry Hydrants**

17			Saint Peters Church 9201 Church Street	39.29.218	77.14.499	4.5 Male
	Location:	Parish Hall Parking Lot				
	Other Info:	Buried Tank				
		Est Flow 500gpm Capacity 20,000 gal Tank				
17			12027 South St	39.23.032	77.16.382	4.5 Male
	Location:	At Station 17				
	Other Info:	Est Flow 500gpm Capacity 10,000gal Tank filled by rain water				
18	39.36.57	77.22.45	8316 Rocky Ridge Rd	36.36.959	77.22.747	4" Male
	Location:	Fire Pond in Graceham				
	Other Info:	Est Flow 600gpm Est Capacity 78,000gals				
18	39.36.57	77.22.45	8316 Rocky Ridge Rd	36.36.959	77.22.747	4" Male
	Location:	Fire Pond in Graceham				
	Other Info:	Est Flow 600gpm Est Capacity 78,000gals				
18	39.36.35	77.21.6	Old Frederick Rd, near Loys Station covered bridge	39.36.583	77.21.113	6" Male
	Location:	Prior to covered bridge				
	Other Info:	Listed as Draft Site 3				
		NOTE needs cap needs work done around pipe in creek NO FLOW				
18	39.39.9	77.21.29	Intersection of Mud College & Orndorff Roads	39.39.167	77.21.437	6" Male
	Location:	Next to 15231 Mud Collage Rd				
	Other Info:	Est Flow 900gpm Est Capacity 395,910gals				

**Frederick County
Dry Hydrants**

Fire Sta	Lat	Long	Location	Lat	Long	Size
20	39.22.49	77.28.19	5509 Mount Zion Rd.	39.22.789	77.28.386	5"Female
	Location:	Behind Gladhill Tractor Complex				
	Other Info:	Est Flow 600gpm Est Capacity 1,772,370gals				
21	39.37.29	77.32.40	14109 Pleasant Valley Road	39.40.538	77.27.503	6"Female
	Location:	Between 14314 and 14233 Pleasant Vally Rd				
	Other Info:	Est Flow 600gpm Est Capacity 725,625gals				
22	39.30.36	77.24.32	10132 Hansonville Road	39.30.684	77.24.520	6"Female
	Location:	Lynfield Events Complex				
	Other Info:	Est Flow 1000gpm Est Capacity 1,198,372gals				
22	39.31.31	77.23.53	7705 Utica Road, near Utica Covered Bridge	39.32.091	77.24.784	6" Male
	Location:					
	Other Info:	NOTE Next to 30,000lb bridge				
		NOTE No flow needs work around pipe in creek				
22	39.32.6	77.24.47	10940 Hessong Bridge Rd,(across from)	39.32.082	77.24.812	6" Male
	Location:					
	Other Info:	NOTE No flow air leak in fitting Capacity unlimited in Fishing Creek				

**Frederick County
Dry Hydrants**

				Verified		Connection
Fire Sta	Lat	Long	Location	Lat	Long	Size
23	39.16.52	77.21.33	On bridge at Covell Rd, near Thurston Rd	39.16.861	77.21.534	6" Male
	Location:	Far left side of bridge from Thurston Rd				
	Other Info:	Est Flow 950gpm Est Capacity unlimited in Bennett Creek				
23	Location:		Sugarloft Mountain Rd/ Comus Rd	39.16.856	77.21.531	4.5 Male
	Location:	At pond at the Stronghold				
	Other Info:	Est Flow 900gpm Est Capacity 1,250,000gals				
25	39.21.30	77.15.56	11441 Weller Road	39.38.993	77.16.943	6"Female
	Location:					
	Other Info:	Est Flow 800gpm Est Capacity 1,653,000gals				
PSTC	Location:		8349 Reichs Ford Road	39.22.581	77.22.366	5" Male
	Location:	On Concrete Wall on South side of pond.				
	Other Info:	Hydrants at complex get water from pond, supplied by a pump				
		Will need knox-box key to access gate.				